

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

991 Montague Expwy #207

Milpitas, CA. 95035

TEL: (408) 263-5900

PC 26-116 068 BEM 26-122495

**STRUCTURAL CALCULATIONS
FOR**

**Quantumscape B2 Phase-2.53 Industrial Tool Installations
at**

**Quantumscape Battery, Inc.
1710 Automation Parkway
San Jose, CA 95131**

JOB # 26023.00

June 5th, 2026

CLIENT:

Pacific Crest Engineering



**CITY OF SAN JOSE
BUILDING DIVISION**
B.P. # PC26-116068
DATE 6/9/26.

DISCLAIMER: Structural design of this project by the undersigned was limited to the specific members and details shown in these calculations. Applied Engineering will accept no responsibility for any work not recorded in these calculations.

CONSULTING STRUCTURAL ENGINEERS

Milpitas,
CA

(408) 263-5900

Project	Quantumscape B2 Phase-2.53	Sheet	of
Client	Pacific Crest Engineering, Inc.	Proj No.	26023.00
	Design Criteria	Date	May-26
		By:	ST
		File	DC26023

Table of Contents**Page**

Design criteria

1

Seismic design factors

2

Equipment anchorage calculations

3 - 31

Appendix

A-1

Seismic site factors

A-2 - A5

SSMA capacity table

A-6

Hilti anchor capacity calculations

A-7 - A14

Appendix

B-1

Equipment cut sheets

B-2 - B-6

CONSULTING STRUCTURAL ENGINEERS		Milpitas, CA		(408) 263-5900	
Project	Quantumscape B2 Phase-2.53	Sheet	of		
Client	Pacific Crest Engineering, Inc.	Proj No.	26023.00	Date	May-26
	Design Criteria	By:	ST	File	DC26023

Code: 2025 Edition of California Building Code

Seismic load factors: (Per ASCE7-22)

$$S_s = 1.98 \quad S_{DS} = 1.42$$

$$S_1 = 0.81 \quad S_{D1} = 0.93$$

Lateral analysis:

Seismic for non-structural components & equipment anchorage:

$$F_p = 0.4 I_p S_{DS} W_p (1 + 2.5 (z/h)) (C_{AR}/R_{po} R_{\mu})$$

Equipment & component anchorage & Support							
Component	C_{AR}	R_{po}	R_{μ}	I_p	Ω_0	F_p/W_p	
						LRFD	ASD
Equipment on Grade ($I_p=1.0$)	1.0	1.5	1.0	1.0	2.0	0.428	-
Equipment on Grade ($I_p=1.5$)	1.0	1.5	1.0	1.5	2.0	0.642	-

Structural Steel members:

ASTM A36, $F_y=36\text{ksi}$ (Channels, angles or other rolled shapes)

ASTM A307 (Machine Bolts)

ASTM A276 (S.S. Shapes & PL.)

Concrete:

$F_c' = 3,000 \text{ psi}$

Expansion Anchors:

Hilti Kwik Bolt- TZ2 Concrete Expansion Anchors, ICC #ESR-4266

NOTE: Manufacturer's software has been utilized to calculate the capacity of typical anchors that are used throughout the calculations and are included in the Appendix section for reference. Loads applied as software inputs are arbitrary. Actual loads & unity equations are calculated & checked within the main body of calculations

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Seismic Factors	By: ST	File EA26023

Code: 2025 Edition of California Building Code

Seismic factors:

$$S_S = 1.98$$

$$S_1 = 0.81$$

$$S_{ms} = 2.14$$

$$S_{M1} = 1.39$$

$$S_{DS} = 2/3 * S_{MS} = 1.43$$

$$S_{D1} = 2/3 * S_{M1} = 0.93$$

Seismic (@ grade level)

$$I_p = 1.0$$

$$F_p = \frac{0.4 S_{DS} I_p W_p}{R_\mu} [1 + 2.5 (z/h)] [C_{AR}/R_{po}]$$

$$C_{AR} = 1.0$$

$$R_{po} = 1.5$$

$$\Omega_{0p} = 2.0$$

$$R_\mu = 1.0$$

$$I_p = 1.0 \text{ Component Importance factor}$$

$$z = 0.0 \text{ @ point of attachment}$$

$$h = 25.0 \text{ average roof height}$$

$$F_p = \frac{0.571}{1.0} \times (1 + 0) \times 0.67 W_p = 0.380 W_p$$

$$F_{pmin} = 0.3 S_{DS} I_p W_p = 0.30 \times 1.427 \times 1.0 W_p = 0.428 W_p \quad \textbf{GOVERNS}$$

$$F_{pmax} = 1.6 S_{DS} I_p W_p = 1.6 \times 1.427 \times 1.0 W_p = 2.28 W_p$$

$$F_p = 0.428 W_p \quad (\text{LRFD Design level})$$

Seismic (@ grade level)

$$I_p = 1.5$$

$$F_p = \frac{0.4 S_{DS} I_p W_p}{R_\mu} [1 + 2.5 (z/h)] [C_{AR}/R_{po}]$$

$$C_{AR} = 1.0$$

$$R_{po} = 1.5$$

$$\Omega_{0p} = 2.0$$

$$R_\mu = 1.0$$

$$I_p = 1.5 \text{ Component Importance factor}$$

$$z = 0.0 \text{ @ point of attachment}$$

$$h = 25.0 \text{ average roof height}$$

$$F_p = \frac{0.856}{1.0} \times (1 + 0) \times 0.67 W_p = 0.571 W_p$$

$$F_{pmin} = 0.3 S_{DS} I_p W_p = 0.30 \times 1.427 \times 1.5 W_p = 0.642 W_p \quad \textbf{GOVERNS}$$

$$F_{pmax} = 1.6 S_{DS} I_p W_p = 1.6 \times 1.427 \times 1.5 W_p = 3.42 W_p$$

$$F_p = 0.642 W_p \quad (\text{LRFD Design level})$$

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project	Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client	Pacific Crest Engineering	Proj No.	26023 Date Mar-26
Furnace		By:	ST File EA26023

Code: 2025 Edition of California Building Code

Lateral Forces: (LRFD)

$$\text{Use } F_p = 0.642 W_p$$

$$S_{DS} = 1.427$$

$$\Omega_0 = 2$$

Equipment info:

Height	$h = 87.9$ in	$= 7.33$ ft	$h_{cog} = 3.60$ ft	(c.o.g. = 43.1")
Width	$w = 40.0$ in	$= 3.33$ ft	$w_{cog} = 1.54$ ft	(c.o.g. = 18.5")
Length	$l = 49.5$ in	$= 4.13$ ft	$l_{cog} = 2.06$ ft	
Weight	$W = 10000$ lbs			

$$F_p = 0.642 \times 10000 = 6420 \text{ lbs}$$

$$\Omega_0 F_p = 2.000 \times 6420 = 12840 \text{ lbs}$$

$$M_{ot} = F_p \times h_{cog} = 6420 \times 3.60 = 23106.1 \text{ lb.ft}$$

$$M_{ot_om} = \Omega_0 \times F_p \times h_{cog} = 2.0 \times 6420 \times 3.60 = 46212.2 \text{ lb.ft}$$

$$M_r = (0.9 - 0.2 S_{DS}) W w_{cog} = 0.61 \times 10000 \times 1.54 = 9476 \text{ lb.ft}$$

$$n = 2 \text{ No. of base plates resisting tension}$$

$$m = 4 \text{ No. of base plates resisting shear}$$

Calculations for concrete anchors:

For LC including overstrength factor

Uplift at each base plate

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{46212.2 - 9476.1}{3.33 \times 2} = 5510.4 \text{ lb per anch}$$

Overturning

Shear at each base plate

$$V = \frac{\Omega_0 F_p}{m} = \frac{12840}{4} = 3210.0 \text{ lb per anch}$$

Anchor Loads

$$\text{Try } g = 4 \text{ Anchor(s) at each base plate}$$

Check Unity Equation

$$N_{ua} = 1 \times T = 5510 \text{ lbs} \quad V_{ua} = 1 \times V = 3210 \text{ lbs}$$

TRY: 1/2" Stainless Steel HILTI KB-TZ2 w/ 3 1/4" Eff. Embd.

(See Hilti PROFIS outputs in following pages)

**USE: 4 x 1/2" Stainless Steel HILTI KB-TZ2 w/ 3 1/4" Eff. Embd.
at each base plate**

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Furnace - BP

Page:

Specifier:

E-Mail:

Date:

1


5/22/2026

Specifier's comments:

1 Input data

Anchor type and diameter:	Kwik Bolt TZ2 - SS 304 1/2 (3 1/4) hnom3
Item number:	2210262 KB-TZ2 1/2x5 1/2 SS304
Specification text:	HILTI Ø 1/2 IN KWIK BOLT TZ2 - SS 304 WITH 3.75 IN NOMINAL EMBEDMENT DEPTH PER ICC-ES ESR-4266 , HAMMER DRILL BIT INSTALLATION PER MPII
Effective embedment depth:	$h_{ef,act} = 3.250$ in., $h_{nom} = 3.750$ in.
Material:	AISI 304
Evaluation Service Report:	ESR-4266
Issued Valid:	12/1/2025 12/1/2027
Proof:	Design Method ACI 318-19 / Mech
Shear edge breakout verification:	Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 1.125$ in.
Anchor plate ^R :	$l_x \times l_y \times t = 10.750$ in. x 16.500 in. x 1.125 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 3000 , $f_c' = 3,000$ psi; $h = 6.000$ in.
Installation:	Hammer drilled hole, Installation condition: Dry
Reinforcement:	tension: not present, shear: not present; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.10.5.3 (d)) Shear load: yes (17.10.6.3 (c))

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [kip, ft.kip]


Hilti PROFIS Engineering 3.1.31

www.hilti.com

Company:		Page:	2
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Furnace - BP	Date:	5/22/2026
Fastening point:			

1.1 Design results

Case	Description	Forces [kip] / Moments [ft.kip]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 5.600; $V_x = 0.000$; $V_y = 3.300$; $M_x = 0.00000$; $M_y = 0.00000$; $M_z = 0.00000$;	yes	56

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|

Furnace - BP

Page:

Specifier:

E-Mail:

Date:

3

5/22/2026

2 Proof I Utilization (Governing Cases)

		Design values [kip]		Utilization		
Loading	Proof	Load	Capacity	β_N / β_V [%]	Status	
Tension	Concrete Breakout Failure	5.600	10.093	56 / -	OK	
Shear	Steel Strength	0.825	5.426	- / 16	OK	
Loading		β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads		0.555	0.152	5/3	42	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

www.hilti.com**Company:****Address:****Phone | Fax:****Design:****Fastening point:**

|

Furnace - BP

Page:**Specifier:****E-Mail:****Date:****4****5/22/2026**

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Electrical Cabinet	By: ST	File EA26023

Code: 2025 Edition of California Building Code

Lateral Forces: (LRFD)

$$\text{Use } F_p = 0.428 W_p$$

$$S_{DS} = 1.427$$

$$\Omega_0 = 2$$

Equipment info:

Height	$h = 84.0$	in	=	7.00	ft	$h_{cog} = 3.94$	ft	(c.o.g. = 47.3")
Width	$w = 18.0$	in	=	1.50	ft	$w_{cog} = 0.74$	ft	(c.o.g. = 8.9")
Length	$l = 101.7$	in	=	8.47	ft	$l_{cog} = 4.53$	ft	(c.o.g. = 54.4")
Weight	$W = 2350$	lbs						

$$F_p = 0.428 \times 2350 = 1006 \text{ lbs}$$

$$\Omega_0 F_p = 2.000 \times 1006 = 2012 \text{ lbs}$$

$$M_{ot} = F_p \times h_{cog} = 1006 \times 3.94 = 3966.2 \text{ lb.ft}$$

$$M_{ot_om} = \Omega_0 \times F_p \times h_{cog} = 2.0 \times 1006 \times 3.94 = 7932.4 \text{ lb.ft}$$

$$M_r = (0.9 - 0.2 S_{DS}) W w_{cog} = 0.61 \times 2350 \times 0.74 = 1074 \text{ lb.ft}$$

$$n = 1 \text{ No. of base plates resisting tension}$$

$$m = 2 \text{ No. of base plates resisting shear}$$

Calculations for concrete anchors:

For LC including overstrength factor

Uplift at each base plate

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{7932.4 - 1074.3}{1.50 \times 1} = 4572.1 \text{ lb per anch}$$

Overturning**Shear at each base plate**

$$V = \frac{\Omega_0 F_p}{m} = \frac{2012}{2} = 1005.8 \text{ lb per anch}$$

Anchor Loads

$$\text{Try } g = 4 \text{ Anchor(s) at each base plate}$$

Check Unity Equation

$$N_{ua} = 1 \times T = 4572 \text{ lbs} \quad V_{ua} = 1 \times V = 1006 \text{ lbs}$$

TRY: 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.

(See Hilti PROFIS outputs in following pages)

**USE: 4 x 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.
at each base plate**

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Electrical Cabinet - BP

Page:

Specifier:

E-Mail:

Date:

1

5/22/2026

Specifier's comments:

1 Input data

Anchor type and diameter:
Item number:
Specification text:

Kwik Bolt TZ2 - SS 304 1/2 (2 1/2) hnom2

2210260 KB-TZ2 1/2x3 3/4 SS304

HILTI Ø 1/2 IN KWIK BOLT TZ2 - SS 304
WITH 3 IN NOMINAL EMBEDMENT DEPTH
PER ICC-ES ESR-4266 , HAMMER DRILL BIT
INSTALLATION PER MPII

Effective embedment depth:
Material:
Evaluation Service Report:
Issued | Valid:
Proof:
Shear edge breakout verification:
Stand-off installation:
Anchor plate^R:
Profile:
Base material:
Installation:
Reinforcement:
Seismic loads (cat. C, D, E, or F)
 $h_{ef,act} = 2.500 \text{ in.}$, $h_{nom} = 3.000 \text{ in.}$

AISI 304

ESR-4266

12/1/2025 | 12/1/2027

Design Method ACI 318-19 / Mech

Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)

 $e_b = 0.000 \text{ in.}$ (no stand-off); $t = 0.188 \text{ in.}$
 $l_x \times l_y \times t = 10.000 \text{ in.} \times 18.000 \text{ in.} \times 0.188 \text{ in.}$; (Recommended plate thickness: not calculated)

no profile


cracked concrete, 3000, $f'_c = 3,000 \text{ psi}$; $h = 6.000 \text{ in.}$
Hammer drilled hole, Installation condition: Dry
tension: not present, **shear:** not present; no supplemental splitting reinforcement present

edge reinforcement: none or < No. 4 bar

Tension load: yes (17.10.5.3 (d))

Shear load: yes (17.10.6.3 (c))

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [kip, ft.kip]


Hilti PROFIS Engineering 3.1.31www.hilti.com

Company:

Address:

Phone / Fax:

Design:

Fastening point:

|
Electrical Cabinet - BP

Page:

Specifier:

E-Mail:

Date:

2

5/22/2026

1.1 Design results

Case	Description	Forces [kip] / Moments [ft.kip]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 4.600; $V_x = 1.010$; $V_y = 0.000$; $M_x = 0.00000$; $M_y = 0.00000$; $M_z = 0.00000$;	yes	52

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Electrical Cabinet - BP

Page:

Specifier:

E-Mail:

Date:

3

5/22/2026

2 Proof | Utilization (Governing Cases)

Loading	Proof	Design values [kip]		Utilization	
		Load	Capacity	β_N / β_V [%]	Status
Tension	Concrete Breakout Failure	4.600	8.865	52 / -	OK
Shear	Steel Strength	0.253	5.426	- / 5	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.519	0.047	5/3	35	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!



www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Electrical Cabinet - BP

Page:

Specifier:

E-Mail:

Date:

4

5/22/2026

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Gas Panel	By: ST	File EA26023

Code: 2025 Edition of California Building Code

Lateral Forces: (LRFD)

$$\text{Use } F_p = 0.642 W_p$$

$$S_{DS} = 1.427$$

$$\Omega_0 = 2$$

Equipment info:**Analysis for Seismic load parallel to short dim. Of equipment**

Height	$h = 52.5$	in	=	4.38	ft	$h_{cog} = 2.19$	ft
Width	$w = 25.1$	in	=	2.09	ft	$w_{cog} = 1.05$	ft
Length	$l = 34.8$	in	=	2.90	ft	$l_{cog} = 1.45$	ft
Weight	$W = 375$	lbs					

$$F_p = 0.642 \times 375 = 241 \text{ lbs}$$

$$\Omega_0 F_p = 2.0 \times 241 = 482 \text{ lbs}$$

$$M_{ot} = F_p \times h_{cog} = 241 \times 2.2 = 527 \text{ lb.ft}$$

$$M_{ot_om} = \Omega_0 \times F_p \times h_{cog} = 2.0 \times 241 \times 2.19 = 1054 \text{ lb.ft}$$

$$M_r = (0.9-0.2SDS) W w_{cog} = 0.61 \times 375 \times 1.05 = 241 \text{ lb.ft}$$

$$n = 2 \text{ No. of clip(s) resisting tension}$$

$$m = 2 \text{ No. of clip(s) resisting shear}$$

Calculations for concrete anchors:**For LC including overstrength factor****Uplift at clip**

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{1054 - 241}{2.09 \times 2} = 194.0 \text{ lb per Clip Overturning}$$

Shear at clip

$$V = \frac{\Omega_0 F_p}{m} = \frac{482}{2} = 240.8 \text{ lb per Clip}$$

Calculations for concrete anchors:**Analysis for Seismic load parallel to long dim. Of equipment**

Width	$w = 34.8$	in	=	2.90	ft	$w_{cog} = 1.45$	ft
-------	------------	----	---	------	----	------------------	----

$$M_r = (0.9-0.2SDS) W w_{cog} = 0.61 \times 375 \times 1.45 = 334 \text{ lb.ft}$$

$$n = 2 \text{ No. of clip(s) resisting tension}$$

$$m = 2 \text{ No. of clip(s) resisting shear}$$

Uplift at clip

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{1054 - 334}{2.90 \times 2} = 124 \text{ lb per Clip Overturning}$$

Shear at clip

$$V = \frac{\Omega_0 F_p}{m} = \frac{482}{2} = 240.8 \text{ lb per Clip}$$

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Gas Panel	By: ST	File EA26023

Applied Loads Worst Condition

$$F_x = 240.8 \text{ lbs}$$

$$F_y = 194.0 \text{ lbs}$$

Dimensions

$$b_1 = 5.00 \text{ in}$$

$$b_2 = 1.50 \text{ in}$$

$$h = 2.00 \text{ in}$$

$$b_3 = 3.00 \text{ in}$$


Anchor LoadsTry $g = 2$ Anchor(s) at each clip

$$T = \frac{F_y \times b_1 + F_x \times h}{b_2 \times g} = 484 \text{ lbs}$$

$$V_1 = \text{Sqrt} [(F_x/g)^2 + (F_x \cdot (b_1 - b_2)/b_3)^2] = 306 \text{ lbs} \quad F_x \text{ Par. To bolts}$$

$$V_2 = F_x / g = 120 \text{ lbs} \quad F_x \text{ Perp. To bolts}$$

$$V_{\max} = 306 \text{ lbs}$$

**Check Unity Equation**

$$N_{ua} = 1 \times T = 484 \text{ lbs} \quad V_{ua} = 1 \times V = 306 \text{ lbs}$$

TRY: 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.

W/ 3 inches spacing

$$\begin{aligned} \phi N_n &= 3103 \times 0.5 = 1552 \text{ lb/Anch Tension} \\ \phi V_n &= 8911 \times 0.5 = 4455.5 \text{ lb/Anch Shear} \end{aligned} \quad \text{(See Hilti PROFIS anchor capacity calcs in following pages)}$$

$$\frac{N_{ua}}{\phi N_n} + \frac{V_{ua}}{\phi V_n} = \frac{484}{1552} + \frac{306}{4456} = 0.38 < 1.2 \text{ OK} \quad 32\%$$

**USE: 2 x 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.
at each clip**

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Gas Panel	By: ST	File EA26023

Check Clip Bending**Analysis for Seismic load parallel to short dim. Of equipment****Uplift at clip**

$$T = \frac{M_{ot} - M_r}{w^* n} = \frac{527}{2.09} - \frac{241}{2} = 68.2 \quad \text{lb per Clip}$$

Shear at clip

$$V = \frac{F_p}{m} = \frac{241}{2} = 120.4 \quad \text{lb per Clip}$$

Analysis for Seismic load parallel to long dim. Of equipment**Uplift at clip**

$$T = \frac{M_{ot} - M_r}{w^* n} = \frac{527}{2.90} - \frac{334}{2} = 33 \quad \text{lb per Clip}$$

Overturning

Shear at clip

$$V = \frac{F_p}{m} = \frac{241}{2} = 120.4 \quad \text{lb per Clip}$$

Applied Loads Worst Condition

$$F_x = 120.4 \quad \text{lbs}$$

$$F_y = 68.2 \quad \text{lbs}$$

Check Clip Bending

$$\phi = 0.9$$

$$M_u = F_y(b_1 - b_2) + F_x(h) = 238.62 + 240.75 = 0.479 \quad \text{k-in}$$

Angle bending profile:

$$\text{min bending width } w = 4.5 \quad \text{in} \quad \text{thickness } t = 1/4 \quad \text{in} \quad F_y = 36 \quad \text{ksi}$$

$$Z = wt^2/4 = 0.070 \quad \text{in}^3$$

$$\phi M_n = \phi Z F_y = 2.278 \quad \text{k-in} > 0.479 \quad \text{k-in} \quad \text{OKAY}$$

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Gas Panel - Z-clip

Page:

Specifier:

E-Mail:

Date:

1


5/22/2026

Specifier's comments:

1 Input data

Anchor type and diameter:	Kwik Bolt TZ2 - SS 304 1/2 (2 1/2) hnom2
Item number:	2210260 KB-TZ2 1/2x3 3/4 SS304
Specification text:	HILTI Ø 1/2 IN KWIK BOLT TZ2 - SS 304 WITH 3 IN NOMINAL EMBEDMENT DEPTH PER ICC-ES ESR-4266 , HAMMER DRILL BIT INSTALLATION PER MPII
Effective embedment depth:	$h_{ef,act} = 2.500$ in., $h_{nom} = 3.000$ in.
Material:	AISI 304
Evaluation Service Report:	ESR-4266
Issued Valid:	12/1/2025 12/1/2027
Proof:	Design Method ACI 318-19 / Mech
Shear edge breakout verification:	Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.250$ in.
Anchor plate ^R :	$l_x \times l_y \times t = 3.000$ in. x 4.500 in. x 0.250 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 3000 , $f'_c = 3,000$ psi; $h = 6.000$ in.
Installation:	Hammer drilled hole, Installation condition: Dry
Reinforcement:	tension: not present, shear: not present; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.10.5.3 (d)) Shear load: yes (17.10.6.3 (c))

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [klp, ft.klp]


Hilti PROFIS Engineering 3.1.31www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Gas Panel - Z-clip

Page:

Specifier:

E-Mail:

Date:

2

5/22/2026

1.1 Design results

Case	Description	Forces [kip] / Moments [ft.kip]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1.000; V _x = 1.000; V _y = 0.000; M _x = 0.00000; M _y = 0.00000; M _z = 0.00000;	yes	33

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Gas Panel - Z-clip

Page:

Specifier:

E-Mail:

Date:

3

5/22/2026

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [kip]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Concrete Breakout Failure	1.000	3.103	33 / -	OK
Shear	Pryout Strength	1.000	8.911	- / 12	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.322	0.112	5/3	18	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

www.hilti.com**Company:****Address:****Phone | Fax:****Design:****Fastening point:**|
Gas Panel - Z-clip**Page:****Specifier:****E-Mail:****Date:****4**

5/22/2026

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Transformer	By: ST	File EA26023

Code: 2025 Edition of California Building Code

Lateral Forces: (LRFD)

$$\text{Use } F_p = 0.428 W_p$$

$$S_{DS} = 1.427$$

$$\Omega_0 = 2$$

Equipment info:

$$\text{Height } h = 44.0 \text{ in} = 3.67 \text{ ft} \quad h_{cog} = 1.83 \text{ ft}$$

$$\text{Width } w = 23.3 \text{ in} = 1.94 \text{ ft} \quad w_{cog} = 0.97 \text{ ft}$$

$$\text{Length } l = 25.0 \text{ in} = 2.08 \text{ ft}$$

$$\text{Weight } W = 1290 \text{ lbs}$$

$$F_p = 0.428 \times 1290 = 552 \text{ lbs}$$

$$\Omega_0 F_p = 2.000 \times 552 = 1104 \text{ lbs}$$

$$M_{ot} = F_p \times h_{cog} = 552 \times 1.83 = 1012.2 \text{ lb.ft}$$

$$M_{ot_om} = \Omega_0 \times F_p \times h_{cog} = 2.0 \times 552 \times 1.83 = 2024.4 \text{ lb.ft}$$

$$M_r = (0.9 - 0.2 S_{DS}) W w_{cog} = 0.61 \times 1290 \times 0.97 = 768 \text{ lb.ft}$$

$$n = 2 \text{ No. of anch(s) resisting tension}$$

$$m = 4 \text{ No. of anch(s) resisting shear}$$

Calculations for concrete anchors:

For LC including overstrength factor

Uplift at anchor

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{2024.4 - 768.1}{1.94 \times 2} = 324.2 \text{ lb per anch}$$

Shear at anchor

$$V = \frac{\Omega_0 F_p}{m} = \frac{1104}{4} = 276.1 \text{ lb per anch}$$

Check Unity Equation

$$N_{ua} = 1 \times T = 324 \text{ lbs} \quad V_{ua} = 1 \times V = 276 \text{ lbs}$$

TRY: 5/8" Stainless Steel HILTI KB-TZ2 w/ 2 3/4" Eff. Embd.

$$\phi N_n = 2557 \times 1 = 2557 \text{ lb/Anch Tension (See Hilti PROFIS outputs in appendix)}$$

$$\phi V_n = 7344 \times 1 = 7344 \text{ lb/Anch Shear}$$

$$\frac{N_{ua}}{\phi N_n} + \frac{V_{ua}}{\phi V_n} = \frac{324}{2557} + \frac{276}{7344} = 0.16 < 1.2 \text{ OK}$$

14%

USE: 5/8" Stainless Steel HILTI KB-TZ2 w/ 2 3/4" Eff. Embd.

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Unwind/Rewind	By: ST	File EA26023

Code: 2025 Edition of California Building Code

Lateral Forces: (LRFD)

$$\text{Use } F_p = 0.428 W_p$$

$$S_{DS} = 1.427$$

$$\Omega_0 = 2$$

Equipment info:**Analysis for Seismic load parallel to short dim. Of equipment**

$$\text{Height } h = 89.0 \text{ in} = 7.42 \text{ ft} \quad h_{cog} = 3.71 \text{ ft}$$

$$\text{Width } w = 46.4 \text{ in} = 3.86 \text{ ft} \quad w_{cog} = 1.93 \text{ ft}$$

$$\text{Length } l = 53.1 \text{ in} = 4.43 \text{ ft} \quad l_{cog} = 2.21 \text{ ft}$$

$$\text{Weight } W = 2800 \text{ lbs}$$

$$F_p = 0.428 \times 2800 = 1198 \text{ lbs}$$

$$\Omega_0 F_p = 2.0 \times 1198 = 2397 \text{ lbs}$$

$$M_{ot} = F_p \times h_{cog} = 1198 \times 3.7 = 4444 \text{ lb.ft}$$

$$M_{ot_om} = \Omega_0 \times F_p \times h_{cog} = 2.0 \times 1198 \times 3.71 = 8888 \text{ lb.ft}$$

$$M_r = (0.9-0.2SDS) W w_{cog} = 0.61 \times 2800 \times 1.93 = 3324 \text{ lb.ft}$$

$$n = 2 \text{ No. of clip(s) resisting tension}$$

$$m = 4 \text{ No. of clip(s) resisting shear}$$

Calculations for concrete anchors:**For LC including overstrength factor****Uplift at clip**

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{8888 - 3324}{3.86 \times 2} = 720.1 \text{ lb per Clip}$$

Overtaking

Shear at clip

$$V = \frac{\Omega_0 F_p}{m} = \frac{2397}{4} = 599.2 \text{ lb per Clip}$$

Calculations for concrete anchors:**Analysis for Seismic load parallel to long dim. Of equipment**

$$\text{Width } w = 53.1 \text{ in} = 4.43 \text{ ft} \quad w_{cog} = 2.21 \text{ ft}$$

$$M_r = (0.9-0.2SDS) W w_{cog} = 0.61 \times 2800 \times 2.21 = 3811 \text{ lb.ft}$$

$$n = 2 \text{ No. of clip(s) resisting tension}$$

$$m = 4 \text{ No. of clip(s) resisting shear}$$

Uplift at clip

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{8888 - 3811}{4.43 \times 2} = 573 \text{ lb per Clip}$$

Overtaking

Shear at clip

$$V = \frac{\Omega_0 F_p}{m} = \frac{2397}{4} = 599.2 \text{ lb per Clip}$$

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of	
Client Pacific Crest Engineering	Proj No.	26023	Date Mar-26
Unwind/Rewind	By:	ST	File EA26023

Applied Loads Worst Condition

$$F_x = 599.2 \text{ lbs}$$

$$F_y = 720.1 \text{ lbs}$$

Dimensions

$$b_1 = 5.00 \text{ in}$$

$$b_2 = 1.50 \text{ in}$$


$$h = 2.00 \text{ in}$$

$$b_3 = 5.00 \text{ in}$$

Anchor LoadsTry $g = 2$ Anchor(s) at each clip

$$T = \frac{F_y \times b_1 + F_x \times h}{b_2 \times g} = 1600 \text{ lbs}$$

$$\left\{ \begin{array}{l} V_1 = \text{Sqrt} [(F_x/g)^2 + (F_x \cdot (b_1 - b_2)/b_3)^2] = 515 \text{ lbs} \quad \text{Fx Par. To bolts} \\ V_2 = F_x / g = 300 \text{ lbs} \quad \text{Fx Perp. To bolts} \end{array} \right\} V_{\max} = 515 \text{ lbs}$$

**Check Unity Equation**

$$N_{ua} = 1 \times T = 1600 \text{ lbs} \quad V_{ua} = 1 \times V = 515 \text{ lbs}$$

TRY: 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.

W/ 5 inches spacing

$$\begin{array}{lclclcl} \phi N_n = 3694 & \times & 0.5 & = & 1847 \text{ lb/Anch} & \text{Tension} \\ \phi V_n = 10609 & \times & 0.5 & = & 5304.5 \text{ lb/Anch} & \text{Shear} \end{array} \quad \begin{array}{l} \text{(See Hilti PROFIS anchor capacity calcs} \\ \text{in following pages)} \end{array}$$

$$\frac{N_{ua}}{\phi N_n} + \frac{V_{ua}}{\phi V_n} = \frac{1600}{1847} + \frac{515}{5305} = 0.96 < 1.2 \text{ OK}$$

80%

**USE: 2 x 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.
at each clip**

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client Pacific Crest Engineering	Proj No. 26023	Date Mar-26
Unwind/Rewind	By: ST	File EA26023

Check Clip Bending**Analysis for Selsmic load parallel to short dim. Of equipment****Uplift at clip**

$$T = \frac{M_{ot} - M_r}{w \cdot n} = \frac{4444 - 3324}{3.86 \times 2} = 144.9 \text{ lb per Clip}$$

Shear at clip

$$V = \frac{F_p}{m} = \frac{1198}{4} = 299.6 \text{ lb per Clip}$$

Analysis for Selsmic load parallel to long dim. Of equipment**Uplift at clip**

$$T = \frac{M_{ot} - M_r}{w \cdot n} = \frac{4444 - 3811}{4.43 \times 2} = 71 \text{ lb per Clip}$$

Overturning

Shear at clip

$$V = \frac{F_p}{m} = \frac{1198}{4} = 299.6 \text{ lb per Clip}$$

Applied Loads Worst Condition

$$F_x = 299.6 \text{ lbs}$$

$$F_y = 144.9 \text{ lbs}$$

Check Clip Bending

$$\phi = 0.9$$

$$M_u = F_y(b_1 - b_2) + F_x(h) = 507.16 + 599.2 = 1.106 \text{ k-in}$$

Angle bending profile:

$$\text{min bending width } w = 6 \text{ in} \quad \text{thickness } t = 1/4 \text{ in} \quad F_y = 36 \text{ ksi}$$

$$Z = wt^2/4 = 0.094 \text{ in}^3$$

$$\phi M_n = \phi Z F_y = 3.038 \text{ k-in} > 1.106 \text{ k-in} \quad \text{OKAY}$$

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Unwind/Rewind - Z-Clip

Page:

Specifier:

E-Mail:

Date:

1


5/22/2026

Specifier's comments:

1 Input data

Anchor type and diameter:
Item number:
Specification text:
Kwik Bolt TZ2 - SS 304 1/2 (2 1/2) hnom2
2210261 KB-TZ2 1/2x4 1/2 SS304
**HILTI Ø 1/2 IN KWIK BOLT TZ2 - SS 304
WITH 3 IN NOMINAL EMBEDMENT DEPTH
PER ICC-ES ESR-4266 , HAMMER DRILL BIT
INSTALLATION PER MPII**

Effective embedment depth:
Material:
Evaluation Service Report:
Issued | Valid:
Proof:
Shear edge breakout verification:
Stand-off installation:
Anchor plate^R:
Profile:
Base material:
Installation:
Reinforcement:
 $h_{ef,act} = 2.500 \text{ in.}, h_{nom} = 3.000 \text{ in.}$
AISI 304
ESR-4266
12/1/2025 | 12/1/2027
Design Method ACI 318-19 / Mech
Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)
 $e_b = 0.000 \text{ in. (no stand-off); } t = 0.375 \text{ in.}$
 $l_x \times l_y \times t = 3.000 \text{ in.} \times 8.000 \text{ in.} \times 0.375 \text{ in.; (Recommended plate thickness: not calculated)}$
no profile
cracked concrete, 3000, $f'_c = 3,000 \text{ psi}$; $h = 6.000 \text{ in.}$
Hammer drilled hole, Installation condition: Dry
tension: not present, shear: not present; no supplemental splitting reinforcement present
edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)
Tension load: yes (17.10.5.3 (d))
Shear load: yes (17.10.6.3 (c))
^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [klp, ft.kip]


**Hilti PROFIS Engineering 3.1.31**www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Unwind/Rewind - Z-Clip

Page:

Specifier:

E-Mail:

Date:

2

5/22/2026

1.1 Design results

Case	Description	Forces [kip] / Moments [ft.kip]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1.000; V _x = 1.000; V _y = 0.000; M _x = 0.00000; M _y = 0.00000; M _z = 0.00000;	yes	28

www.hilTI.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Unwind/Rewind - Z-Clip

Page:

Specifier:

E-Mail:

Date:

3

5/22/2026

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [kip]		Utilization	
		Load	Capacity	β_N / β_V [%]	Status
Tension	Concrete Breakout Failure	1.000	3.694	28 / -	OK
Shear	Pryout Strength	1.000	10.609	- / 10	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.271	0.094	5/3	14	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
Unwind/Rewind - Z-Clip

Page:

Specifier:

E-Mail:

Date:

4

5/22/2026

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project	Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client	Pacific Crest Engineering	Proj No.	26023 Date Mar-26
ESUC		By:	ST File EA26023

Code: 2025 Edition of California Building Code

Lateral Forces: (LRFD)

$$\text{Use } F_p = 0.428 W_p$$

$$S_{DS} = 1.427$$

$$\Omega_0 = 2$$

Equipment info:

Height	$h = 60.0$	in	=	5.00	ft	$h_{cog} = 2.50$	ft
Width	$w = 19.7$	in	=	1.64	ft	$w_{cog} = 0.82$	ft
Length	$l = 28.3$	in	=	2.36	ft		
Weight	$W = 386$	lbs					

$$F_p = 0.428 \times 386 = 165 \text{ lbs}$$

$$\Omega_0 F_p = 2.000 \times 165 = 330 \text{ lbs}$$

$$M_{ot} = F_p \times h_{cog} = 165 \times 2.50 = 413.0 \text{ lb.ft}$$

$$M_{ot_om} = \Omega_0 \times F_p \times h_{cog} = 2.0 \times 165 \times 2.50 = 826.0 \text{ lb.ft}$$

$$M_r = (0.9 - 0.2 S_{DS}) W w_{cog} = 0.61 \times 386 \times 0.82 = 195 \text{ lb.ft}$$

$$n = 2 \text{ No. of clip(s) resisting tension}$$

$$m = 4 \text{ No. of clip(s) resisting shear}$$

Calculations for concrete anchors:

For LC including overstrength factor

Uplift at clip

$$T = \frac{M_{ot_om} - M_r}{w \times n} = \frac{826.0 - 194.6}{1.64 \times 2} = 192.5 \text{ lb per Clip Overturning}$$

Shear at clip

$$V = \frac{\Omega_0 F_p}{m} = \frac{330}{4} = 82.6 \text{ lb per Clip}$$

Applied Loads

$$F_x = 82.6 \text{ lbs}$$


$$F_y = 192.5 \text{ lbs}$$

Dimensions

$$b_1 = 3.00 \text{ in}$$

$$b_2 = 1.50 \text{ in}$$

$$h = 6.50 \text{ in}$$

**Anchor Loads**

$$T = \frac{F_y \times b_1 + F_x \times h}{b_2} = 743 \text{ lbs}$$

$$V = F_x = 83 \text{ lbs}$$

APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project	Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client	Pacific Crest Engineering	Proj No.	26023 Date Mar-26
ESUC		By:	ST File EA26023

Check Unity Equation

$$N_{ua} = 1 \times T = 743 \text{ lbs} \quad V_{ua} = 1 \times V = 83 \text{ lbs}$$

TRY: 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.

$$\phi N_n = 2216 \times 1 = 2216 \text{ lb/Anch Tension (See Hilti PROFIS outputs in appendix)}$$

$$\phi V_n = 5426 \times 1 = 5426 \text{ lb/Anch Shear}$$

$$\frac{N_{ua}}{\phi N_n} + \frac{V_{ua}}{\phi V_n} = \frac{743}{2216} + \frac{83}{5426} = 0.35 < 1.2 \text{ OK } 29\%$$

**USE: 1 x 1/2" Stainless Steel HILTI KB-TZ2 w/ 2 1/2" Eff. Embd.
at each clip**
Check connection of the clip to equip.:**Uplift at clip**

$$T = \frac{M_{ot} - M_r}{w \cdot n} = \frac{413.0 - 194.6}{1.64 \times 2} = 66.6 \text{ lb per Clip}$$

Shear at clip

$$V = \frac{F_p}{m} = \frac{165}{4} = 41.3 \text{ lb per Clip}$$

Applied Loads

$$F_x = 41.3 \text{ lbs}$$

$$F_y = 66.6 \text{ lbs}$$

Try: 3 x #12 Sheet metal screw(s)


$$t_1 = 3/16 \text{ in Min. Thick. of member in contact w/ screw head or washer}$$

$$t_2 = 20 \text{ gage Min. Thick. of member not in contact w/ screw head or washer}$$

$$F_v = \frac{\text{Sqrt}((F_x)^2 + (F_y)^2)}{3} = 26 \text{ lb Shear in ea. Screw}$$

$$F_t = \frac{41.3}{3} = 14 \text{ lb Tension in ea. Screw}$$

	(ASD)	(LRFD)		(See SSMA Table in appendix)
$P_{s_LRFD} = 188$	$\times 3 \times 0.5 =$	282	> 26 OK	Shear
$P_{t_LRFD} = 95$	$\times 3 \times 0.5 =$	142.5	> 14 OK	Tension

USE: 3 x #12 Sheet metal screw(s) at each clip


APPLIED ENGINEERING

CONSULTING STRUCTURAL ENGINEERS

Milpitas, CA

(408) 263-5900

Project	Q.S. B2 Ph 2.53 - Industrial Tool Installation	Sheet	of
Client	Pacific Crest Engineering	Proj No.	26023
ESUC		Date	Mar-26
		By:	ST
		File	EA26023

Check bending of the clip to equip.:**Clip:** 1

$$\phi = 0.9 \quad \Omega = 1.67$$

Design Method: (LRFD)

$$\psi = 0.90 \quad (\text{LRFD}=\phi, \text{ASD}=1/\Omega)$$

b = 3.00 in Full Plate/Clip Width

h = 6.50 in Plate/Clip Height


t = 0.250 in Plate/Clip thickness

 $F_y = 30000$ psi Minimum Yield Stress of the plate/Clip Material

$$Z_y = \frac{b \times t^2}{4} = \frac{3.00 \times 0.06}{4} = 0.047 \text{ in}^3$$

$$F_{\max} = \frac{\psi \cdot F_y \cdot Z}{h} = \frac{0.9 \cdot 30000 \cdot 0.047}{6.50} = 195 \text{ lb}$$

$$F_{\max} = 194.7 \text{ lb} > F_x = 41.3 \text{ lb} \quad \text{OK} \quad 21\%$$

USE: 0.25" Thk. Clip at each anchor location

APPENDIX - A





ASCE Hazards Report

Address:
1710 Automation Pkwy
San Jose, California
95131

Standard: ASCE/SEI 7-22
Risk Category: II
Soil Class: CD

Latitude: 37.391597
Longitude: -121.883605
Elevation: 79.97279660768584 ft
(NAVD 88)







Site Soil Class: CD

Results:

PGA_M :	0.73	T_L :	12
S_{MS} :	2.14	S_s :	1.98
S_{M1} :	1.39	S_1 :	0.81
S_{DS} :	1.42	V_{S30} :	365
S_{D1} :	0.93		

Seismic Design Category: E



MCE_R Vertical Response Spectrum

Vertical ground motion data has not yet been made available by USGS.

Design Vertical Response Spectrum

Vertical ground motion data has not yet been made available by USGS.



Data Accessed: Fri Mar 06 2026

Date Source:

USGS Seismic Design Maps based on ASCE/SEI 7-22 and ASCE/SEI 7-22 Table 1.5-2. Additional data for site-specific ground motion procedures in accordance with ASCE/SEI 7-22 Ch. 21 are available from USGS.

The ASCE Hazard Tool is provided for your convenience, for informational purposes only, and is provided “as is” and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE Hazard Tool.

Screw Capacities

Table Notes

- Capacities based on AISI S100 Section E4.
- When connecting materials of different steel thicknesses or tensile strengths, use the lowest values. Tabulated values assume two sheets of equal thickness are connected.
- Capacities are based on Allowable Strength Design (ASD) and include safety factor of 3.0.
- Where multiple fasteners are used, screws are assumed to have a center-to-center spacing of at least 3 times the nominal diameter (d).
- Screws are assumed to have a center-of-screw to edge-of-steel dimension of at least 1.5 times the nominal diameter (d) of the screw.
- Pull-out capacity is based on the lesser of pull-out capacity in sheet closest to screw tip or tension strength of screw.
- Pull-over capacity is based on the lesser of pull-over capacity for sheet closest to screw header or tension strength of screw.
- Values are for pure shear or tension loads. See AISI Section E4.5 for combined shear and pull-over.
- Screw Shear (Pss), tension (Pts), diameter, and head diameter are from CFSEI Tech Note (F701-12).
- Screw shear strength is the average value, and tension strength is the lowest value listed in CFSEI Tech Note (F701-12).
- Higher values for screw strength (Pss, Pts), may be obtained by specifying screws from a specific manufacturer.

Allowable Screw Connection Capacity (lbs)

Thickness (Mils)	Design Thickness	Fy Yield (ksi)	Fu Tensile (ksi)	#6 Screw			#8 Screw			#10 Screw			#12 Screw			1/2" Screw		
				(Pss = 643 lbs, Pts = 419 lbs)			(Pss = 1278 lbs, Pts = 586 lbs)			(Pss = 1644 lbs, Pts = 1158 lbs)			(Pss = 2330 lbs, Pts = 2325 lbs)			(Pss = 3048 lbs, Pts = 3201 lbs)		
				0.136" dia, 0.272" Head			0.164" dia, 0.272" Head			0.190" dia, 0.340" Head			0.216" dia, 0.340" Head			0.250" dia, 0.409" Head		
				Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over
18	0.0188	33	33	44	24	84	48	29	84	52	33	105	55	38	105	60	44	127
27	0.0283	33	33	82	37	127	89	43	127	96	50	159	102	57	159	110	66	191
30	0.0312	33	33	95	40	140	103	48	140	111	55	175	118	63	175	127	73	211
33	0.0346	33	45	151	61	140	164	72	195	177	84	265	188	95	265	203	110	318
43	0.0451	33	45	214	79	140	244	94	195	263	109	345	280	124	345	302	144	415
54	0.0566	33	45	214	100	140	344	118	195	370	137	386	394	156	433	424	180	521
68	0.0713	33	45	214	125	140	426	149	195	523	173	386	557	196	545	600	227	656
97	0.1017	33	45	214	140	140	426	195	195	548	246	386	777	280	775	1,016	324	936
118	0.1242	33	45	214	140	140	426	195	195	548	301	386	777	342	775	1,016	396	1,067
54	0.0566	50	65	214	140	140	426	171	195	534	198	386	569	225	625	613	261	752
68	0.0713	50	65	214	140	140	426	195	195	548	249	386	777	284	775	866	328	948
97	0.1017	50	65	214	140	140	426	195	195	548	356	386	777	405	775	1,016	468	1,067
118	0.1242	50	65	214	140	140	426	195	195	548	386	386	777	494	775	1,016	572	1,067

Weld Capacities

Table Notes

- Capacities based on the AISI S100 Specification Sections E2.4 for fillet welds and E2.5 for flare groove welds.
- When connecting materials of different steel thicknesses or tensile strengths, use the lowest values.
- Capacities are based on Allowable Strength Design (ASD).
- Weld capacities are based on E60 electrodes. For material thinner than 68 mil, 0.030" to 0.035" diameter wire electrodes may provide best results.
- Longitudinal capacity is considered to be loading in the direction of the length of the weld.
- Transverse capacity is loading in perpendicular direction of the length of the weld.
- For flare groove welds, the effective throat of weld is conservatively assumed to be less than 2t.
- For longitudinal fillet welds, a minimum value of EQ E2.4-1, E2.4-2, and E2.4-4 was used.
- For transverse fillet welds, a minimum value of EQ E2.4-3 and E2.4-4 was used.
- For longitudinal flare groove welds, a minimum value of EQ E2.5-2 and E2.5-3 was used.

Allowable Weld Capacity (lbs / in)

Thickness (Mils)	Design Thickness	Fy Yield (ksi)	Fu Tensile (ksi)	Fillet Welds		Flare Groove Welds	
				Longitudinal	Transverse	Longitudinal	Transverse
43	0.0451	33	45	499	864	544	663
54	0.0566	33	45	626	1084	682	832
68	0.0713	33	45	789	1365	859	1048
97	0.1017	33	45	1125	1269	- ¹	- ¹
54	0.0566	50	65	905	1566	985	1202
68	0.0713	50	65	1140	1972	1241	1514
97	0.1017	50	65	1269	1269	- ¹	- ¹

¹Weld capacity for material thickness greater than 0.10" requires engineering judgment to determine leg of welds, W1 and W2.

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
General - 5/8"

Page:

Specifier:

E-Mail:

Date:

1

5/22/2026

Specifier's comments:

1 Input data

Anchor type and diameter:

Kwik Bolt TZ2 - SS 304 5/8 (2 3/4) hnom1

Item number:

2210277 KB-TZ2 5/8x4 1/4 SS304

Specification text:

HILTI Ø 5/8 IN KWIK BOLT TZ2 - SS 304
WITH 3.25 IN NOMINAL EMBEDMENT
DEPTH PER ICC-ES ESR-4266 , HAMMER
DRILL BIT INSTALLATION PER MPII

Effective embedment depth:
 $h_{ef,act} = 2.750$ in., $h_{nom} = 3.250$ in.

Material:

AISI 304

Evaluation Service Report:

ESR-4266

Issued | Valid:

12/1/2025 | 12/1/2027

Proof:

Design Method ACI 318-19 / Mech

Shear edge breakout verification:

Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)

Stand-off installation:
 $e_b = 0.000$ in. (no stand-off); $t = 0.250$ in.

Anchor plate^R:
 $l_x \times l_y \times t = 3.000$ in. x 3.000 in. x 0.250 in.; (Recommended plate thickness: not calculated)

Profile:

no profile

Base material:

cracked concrete, 3000, $f'_c = 3,000$ psi; $h = 6.000$ in.

Installation:
Hammer drilled hole, Installation condition: Dry
Reinforcement:

tension: not present, shear: not present; no supplemental splitting reinforcement present


edge reinforcement: none or < No. 4 bar

Seismic loads (cat. C, D, E, or F)

Tension load: yes (17.10.5.3 (d))

Shear load: yes (17.10.6.3 (c))

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [klp, ft.klp]


Hilti PROFIS Engineering 3.1.31www.hilti.com

Company:

Address:

Phone / Fax:

Design:

Fastening point:

|
General - 5/8"

Page:

Specifier:

E-Mail:

Date:

2

5/22/2026

1.1 Design results

Case	Description	Forces [kip] / Moments [ft.kip]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1.000; V _x = 1.000; V _y = 0.000; M _x = 0.00000; M _y = 0.00000; M _z = 0.00000;	yes	40

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
General - 5/8"

Page:

Specifier:

E-Mail:

Date:

3

5/22/2026

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [kip]		Utilization	
		Load	Capacity	β_N / β_V [%]	Status
Tension	Concrete Breakout Failure	1.000	2.557	40 / -	OK
Shear	Pryout Strength	1.000	7.344	- / 14	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.391	0.136	5/3	25	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
General - 5/8"

Page:

Specifier:

E-Mail:

Date:

4

5/22/2026

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
General - 1/2"

Page:

Specifier:

E-Mail:

Date:

1

5/22/2026


Specifier's comments:

1 Input data

Anchor type and diameter:	Kwik Bolt TZ2 - SS 304 1/2 (2 1/2) hnom2
Item number:	2210260 KB-TZ2 1/2x3 3/4 SS304
Specification text:	HILTI Ø 1/2 IN KWIK BOLT TZ2 - SS 304 WITH 3 IN NOMINAL EMBEDMENT DEPTH PER ICC-ES ESR-4266 , HAMMER DRILL BIT INSTALLATION PER MPII
Effective embedment depth:	$h_{ef,act} = 2.500$ in., $h_{nom} = 3.000$ in.
Material:	AISI 304
Evaluation Service Report:	ESR-4266
Issued Valid:	12/1/2025 12/1/2027
Proof:	Design Method ACI 318-19 / Mech
Shear edge breakout verification:	Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.250$ in.
Anchor plate^R:	$l_x \times l_y \times t = 3.000$ in. x 3.000 in. x 0.250 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 3000 , $f'_c = 3,000$ psi; $h = 6.000$ in.
Installation:	Hammer drilled hole, Installation condition: Dry
Reinforcement:	tension: not present, shear: not present; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.10.5.3 (d)) Shear load: yes (17.10.6.3 (c))


^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [kip, ft.kip]



www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
General - 1/2"

Page:

Specifier:

E-Mail:

Date:

2

5/22/2026

1.1 Design results

Case	Description	Forces [kip] / Moments [ft.kip]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 1.000; V _x = 1.000; V _y = 0.000; M _x = 0.00000; M _y = 0.00000; M _z = 0.00000;	yes	46

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|
General - 1/2"

Page:

Specifier:

E-Mail:

Date:

3

5/22/2026

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [kip]		Utilization	
		Load	Capacity	β_N / β_V [%]	Status
Tension	Concrete Breakout Failure	1.000	2.216	46 / -	OK
Shear	Steel Strength	1.000	5.426	- / 19	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.451	0.184	5/3	33	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

|

General - 1/2"

Page:

Specifier:

E-Mail:

Date:

4

5/22/2026

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.



**APPENDIX - B
EQUIPMENT / TOOL
MANUFACTURER INFORMATION**

1

2

3

4



1097

825

827

FURNACE
TOTAL MAX. WT. = 10,000#

INFORMATION CONTAINED IN THIS DOCUMENT IS
CONSIDERED Y QUANTUMSCAPE'S CONFIDENTIAL AND IS
NOT TO BE USED IN ANY MANNER WITHOUT THE EXPRESS
PERMISSION OF QUANTUMSCAPE



TITLE:

ASSEMBLY, OVEN, SINTER

SIZE DWG. NO. REV

B 0234451 COG FOR MJ

SCALE: 1:20 DO NOT SCALE DRAWING SHEET 1 OF 1

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN MILLIMETERS
TOLERANCES UNLESS OTHERWISE SPECIFIED (SM)
X.12 14. XX-0.254. XXX-0.127
INTERPRET DIMENSIONS AND TOLERANCES
PER ASME Y14.5-2009

THIRD ANGLE PROJECTION



MATERIAL

FINISH

TPTAL WEIGHT: 8883 LBS





1

2

3

4


REVISIONS			
ZONE	REV.	DESCRIPTION	DATE
	1	PRELIMINARY	3/25/2026
	2	ADD WIDER DISCONNECT BOX	4/16/2026
	3	ADD NEW RISER CONSTRUCTION METHOD	5/14/2026
			KW
			KW





ELECTRICAL CABINET
TOTAL MAX. WT. = 2,350#

TOTAL WEIGHT
APPROX 2350 LBS

QuantumScope INFORMATION CONTAINED IN THIS DOCUMENT IS CONSIDERED Y QUANTUMSCOPE AS CONFIDENTIAL AND IS NOT TO BE USED IN ANY MANNER WITHOUT THE EXPRESS PERMISSION OF QUANTUMSCOPE		NAME DATE DESIGNED BY DRAWN BY MATERIAL FINISH THIRD ANGLE PROJECTION	TITLE: SCALE: 1:20 SHEET 1 OF 1
SIZE DWG. NO. B PD ASSEMBLY		REV 3	





REVISION HISTORY		
REV	DESCRIPTION	DATE
1.1	ADDED DIMENSIONS AND INPUT/OUTPUT NOTES	03/05/2026
1	INITIAL RELEASE	03/03/2026

GAS PANEL
TOTAL MAX. WT. = 375#

ITEM	QTY	PART NUMBER	TITLE	VENDOR	VENDOR PN
5	8		M10 OVERSIZED WASHER	MCMASTER CARR	91116A170
4	4		M10X1.5 FLANGE NUT	MCMASTER-CARR	90374A116
3	4		M10 X 1.5, L: 90, SSHS BOLT	MCMASTER-CARR	81502A235
2	1	0239228	ST1500 GAS PANEL ASSEMBLY		
1	1	0239177	CC GAS PANEL		

Parts List		3/3/2028		QUANTUMSCAPE	
CHARGES AND TO SURFACES DO NOT SCALE (MM)	11801 CHARGED			CC GAS PANEL	
THIRD ANGLE PROJECTION	10A				
	10B				
DO NOT SCALE (MM)	10C				
DO NOT SCALE (MM)	10D				
DO NOT SCALE (MM)	10E				
DO NOT SCALE (MM)	10F				
DO NOT SCALE (MM)	10G				
DO NOT SCALE (MM)	10H				
DO NOT SCALE (MM)	10I				
DO NOT SCALE (MM)	10J				
DO NOT SCALE (MM)	10K				
DO NOT SCALE (MM)	10L				
DO NOT SCALE (MM)	10M				
DO NOT SCALE (MM)	10N				
DO NOT SCALE (MM)	10O				
DO NOT SCALE (MM)	10P				
DO NOT SCALE (MM)	10Q				
DO NOT SCALE (MM)	10R				
DO NOT SCALE (MM)	10S				
DO NOT SCALE (MM)	10T				
DO NOT SCALE (MM)	10U				
DO NOT SCALE (MM)	10V				
DO NOT SCALE (MM)	10W				
DO NOT SCALE (MM)	10X				
DO NOT SCALE (MM)	10Y				
DO NOT SCALE (MM)	10Z				
DO NOT SCALE (MM)	10AA				
DO NOT SCALE (MM)	10AB				
DO NOT SCALE (MM)	10AC				
DO NOT SCALE (MM)	10AD				
DO NOT SCALE (MM)	10AE				
DO NOT SCALE (MM)	10AF				
DO NOT SCALE (MM)	10AG				
DO NOT SCALE (MM)	10AH				
DO NOT SCALE (MM)	10AI				
DO NOT SCALE (MM)	10AJ				
DO NOT SCALE (MM)	10AK				
DO NOT SCALE (MM)	10AL				
DO NOT SCALE (MM)	10AM				
DO NOT SCALE (MM)	10AN				
DO NOT SCALE (MM)	10AO				
DO NOT SCALE (MM)	10AP				
DO NOT SCALE (MM)	10AQ				
DO NOT SCALE (MM)	10AR				
DO NOT SCALE (MM)	10AS				
DO NOT SCALE (MM)	10AT				
DO NOT SCALE (MM)	10AU				
DO NOT SCALE (MM)	10AV				
DO NOT SCALE (MM)	10AW				
DO NOT SCALE (MM)	10AX				
DO NOT SCALE (MM)	10AY				
DO NOT SCALE (MM)	10AZ				
DO NOT SCALE (MM)	10BA				
DO NOT SCALE (MM)	10BB				
DO NOT SCALE (MM)	10BC				
DO NOT SCALE (MM)	10BD				
DO NOT SCALE (MM)	10BE				
DO NOT SCALE (MM)	10BF				
DO NOT SCALE (MM)	10BG				
DO NOT SCALE (MM)	10BH				
DO NOT SCALE (MM)	10BI				
DO NOT SCALE (MM)	10BJ				
DO NOT SCALE (MM)	10BK				
DO NOT SCALE (MM)	10BL				
DO NOT SCALE (MM)	10BM				
DO NOT SCALE (MM)	10BN				
DO NOT SCALE (MM)	10BO				
DO NOT SCALE (MM)	10BP				
DO NOT SCALE (MM)	10BQ				
DO NOT SCALE (MM)	10BR				
DO NOT SCALE (MM)	10BS				
DO NOT SCALE (MM)	10BT				
DO NOT SCALE (MM)	10BU				
DO NOT SCALE (MM)	10BV				
DO NOT SCALE (MM)	10BW				
DO NOT SCALE (MM)	10BX				
DO NOT SCALE (MM)	10BY				
DO NOT SCALE (MM)	10BZ				
DO NOT SCALE (MM)	10CA				
DO NOT SCALE (MM)	10CB				
DO NOT SCALE (MM)	10CC				
DO NOT SCALE (MM)	10CD				
DO NOT SCALE (MM)	10CE				
DO NOT SCALE (MM)	10CF				

3. PART SHALL BE EXTERNALLY WIPED DOWN WITH ISOPROPYL ALCOHOL

2 TORQUE FASTENER TO 30.0 ± 3.0 FT-LBS (40.7 ± 5.1 N-m)

1. USE KRYTOX E3000 CLEANROOM RATED GREASE AS THREAD LUBRICATION. INSTALL PER MANUFACTURERS INSTRUCTION

NOTES: UNLESS OTHERWISE SPECIFIED



ENERGY EFFICIENT TRANSFORMER

- 3 Phase Isolation
- Dry Type
- ANN Self Cooled

Purchaser:
PO#:
SWO#:
Qty:

W018480
1

Unit Number: MT66504

Coils: Aluminum
Cat. No.: BA150H-X/Z3/MDX
kVA: 150
Primary: 480 Delta Volts
Secondary: 104 Delta Volts
Primary Taps: 2.5 %
-Taps FCAN 2
-Taps FCBN 2
Frequency: 60 Hz
BIL: 10 kV
Insulation Class: 220 °C
Temperature Rise: 150 °C
Impedance: 4.0 %
Min. Efficiency: 98.83 %
(Calculated @ 35% Loaded)
Weight: 1290 Lbs

Drawing for Record

This drawing is a record of our final design for the noted order number.

Windings	For Cable Size	Terminations
Primary @ Front	#6 AWG up to 300MCM	Lugs: 300MCM-6 (1/Ph)
Secondary @ Front	By Customer	Pads*
Ground lugs @ the base of enclosure: 1X 300MCM-6 + 4 ports 2/0-14 AWG		


*NEMA terminal connector dimensions (CG 1-2009 Annex C)

Wiring Connection:

Primary:	H1-H2-H3	Jumpers To:
Voltage	% Tap	
504	105.0	1-1-1
492	102.5	2-2-2
480	100.0	3-3-3
468	97.5	4-4-4
456	95.0	5-5-5


Secondary:

Voltage 104
Connect Loads To:
X1-X2-X3



B-6

- ① - REMOVABLE PANELS FOR EASY ACCESS TO TERMINALS
- ② - LOCATION OF NAMEPLATE





CSA Enclosure:

- 1)- Type 3R (NEMA 3R)
 - Sprinklerproof when the angle between sprinkler heads and opening in the enclosure does not exceed 45 degree from the vertical.
- 2)- Ventilated
- 3)- ASA 61 grey
- 4)- Floor mounting

TRANSFORMER
TOTAL MAX. WT. = 1,290#

Rev.	Remarks	By	Appr. By	Date



Prepared by: AP
Approved by: VS
Date: MAY 14, 2028



UNWIND/REWIND
TOTAL MAX. WT. = 1,290#

ESUC
TOTAL MAX. WT. = 386#

RWH - UNWIND



RWH - REWIND

